

CERTIFICATE of Conformity



Certificate No.: MK 69247412 0001

Test Report No.: 28218252 002

Certificate Holder: HAFLEX Maschinenbau GmbH, Blauberg Ventilatoren
51-53, Eurerer Strasse
D-54294 Trier
Germany

Manufacturer: ---

Product: Centrifugal fans

Identification:	Type Designation:	Rated power input:
	Centro-M 100SL ;	Centro-M 125SL 27W
	Centro-M 100L ;	Centro-M 125L ; 60W
	Centro-MZ 100L ;	Centro-MZ 125L 60W
	Centro-MZ 100	72W
	Centro-M 100 ;	Centro-M 160L 73W
	Centro-M 125 ;	Centro-M 150L ; 75W
	Centro-MZ 150	75W
	Centro-MZ 125 ;	Centro-MZ 160 78W
	Centro-M 150 ;	Centro-M 160 98W
	Centro-M 160max	115W
	Centro-M 150max	116W
	Centro-MZ 250L	134W
	Centro-MZ 200L	139W

Trade Mark:	Blauberg
Rated voltage:	230V~, 50Hz
Degree of protection:	IPX4
Protection class:	I

Tested according to: EN 60335-1:2012
EN 60335-2-80:2003+A1+A2
EN 62233:2008

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:

Budapest, 2014.06.27



CERTIFICATE of Conformity



Certificate No.: MK 69247413 0001

Test Report No.: 28218252 002

Certificate Holder: HAFLEX Maschinenbau GmbH, Blauberg Ventilatoren
51-53, Eurenner Strasse
D-54294 Trier
Germany

Manufacturer: ---

Product: Centrifugal fans

Identification: Type Designation: Rated power input:

Centro-MZ 315L	151W
Centro-MZ 250	152W
Centro-M 200	154W
Centro-MZ 200	157W
CentroM 250L	158W
Centro-M 315	171W
Centro-MZ 315	185W
Centro-M 200max	193W
Centro-M 250	194W
Centro-M 315max	296W

Trade Mark:	Blauberg
Rated voltage:	230V~, 50Hz
Degree of protection:	IPX4
Protection class:	I

Tested according to: EN 60335-1:2012
EN 60335-2-80:2003+A1+A2
EN 62233:2008

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:

Budapest, 2014.06.27

